

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/19/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 012749		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - PAOLI DIALYSIS B. WING _____		(X3) DATE SURVEY COMPLETED R 07/17/2012	
NAME OF PROVIDER OR SUPPLIER PAOLI DIALYSIS				STREET ADDRESS, CITY, STATE, ZIP CODE 555 WEST LONGEST STREET PAOLI, IN 47454			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>Paper compliance to the Initial Life Safety Code Certification conducted on 06/22/12 was completed on 07/17/12.</p> <p>Review Date: 07/17/12</p> <p>Facility Number: 012749 Provider Number: 012749 AIM Number: NA</p> <p>Surveyor: Dennis Austill, Life Safety Code Supervisor</p> <p>Paoli Dialysis was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety from Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 20, New Ambulatory Health Care Occupancies.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.